

Producer Statement (Plumbing Test Only)

Issued to: Gore District Council

29 Bowler Avenue, Gore 9710
PO Box 8, Gore 9740
Phone 03 209 0330
Email building@goredc.govt.nz
www.goredc.govt.nz

Issued by:

(Certifying Plumber)

Registration number:

(I hereby certify that my registration is current)

Phone:

Email:

Building Consent Number:

(This must be completed)

At

(Address of property)

In relation to:

(Description of work i.e. alteration / extension / bathroom etc.)

I have been engaged to undertake the plumbing work on the above building consent. I hereby certify that the work complies with the building consent and that I have undertaken a pressure test for water tightness in accordance with:

NZ Building Code G12/AS1 – 1500kPa for a period of not less than 15 minutes.

AS/NZS 3500.1:2003 – 1500 kPa for a period of not less than 30 minutes.

(tick appropriate box)

and certify that this pressure test passed the indicated method of compliance.

This statement will be accepted and relied on by the Gore District Council for testing only a small bathroom/kitchen, laundry alteration up to a maximum of 20m of pipework in length.

Signed by:

Date:

(The above named person)

Office Use Only

Form filled out correctly:

Yes – put this form on building consent file.

No – if not, pipework is to be tested and viewed by Council inspector. This form to building consent file.

Failed notice left on site. Pre-line not approved. Linings not to be installed – re-inspection required.